

STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

Attachment No. 1

Page 1 of 1

PROPOSED STATE STANDARD,
TITLE 8, CHAPTER 4

Amend Section 2320.2 to read:

§2320.2. Energized Equipment or Systems.

(a) Work shall not be performed on exposed energized parts of equipment or systems until the following conditions are met:

(1) Responsible supervision has determined that the work is to be performed while the equipment or systems are energized.

(2) Involved personnel have received instructions on the work techniques and hazards involved in working on energized equipment.

(3) Suitable personal protective equipment has been provided and is used. ~~Suitable~~ Approved insulated gloves shall be worn for voltages in excess of ~~300 volts, nominal~~ 250 volts to ground.

~~(4) Suitable barriers or approved insulating material shall be provided and used to prevent accidental contact with energized parts.~~

~~(4)(5)~~ (5) Suitable eye protection has been provided and is used.

~~(5)(6)~~ (6) Where required for personnel protection, suitable ~~barriers~~, barricades, tags, or signs are in place ~~for personnel protection~~.

(b) After the required work on an energized system or equipment has been completed, an authorized person shall be responsible for:

(1) Removing from the work area any temporary personnel protective equipment, and

(2) Reinstalling all permanent barriers or covers.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.